

ADDENDUM NO. 1

John A. Tuten & Associates, Architects
4680 Hwy 17 North
Brunswick, GA 31525

GENERAL

1. We are concerned about unknown utilities and services under Mansfield Street. In order to keep post foundations as shallow as possible the following foundation systems are to be used:
 - a. The foundations for the gate posts of the 14' double swing gates to be 36" x 36" by 24" deep.
 - b. All other fence post foundations in the Mansfield Street area should be 24" x 24" by 24" deep.
 - c. The top of these foundations should be level with the top of the curbs.
 - d. Aluminum fence posts to be 21" deep into the 24" footing.

END OF ADDENDUM NO. 1

Attachments:

1812\160\190612AddendumNo1